

(b) after FORM I as so substituted, the following Form shall be inserted, namely:-

"FORM IA

Application Form for Temporary Service Connection

FORM OF REQUISITION FOR TEMPORARY SUPPLY (SINGLE PHASE / THREE PHASE)

[Refer regulation 27(3)]

To

The Designated Engineer

(Address of the Licensee)



Sir,

1. I/We, /Thiru/Tmty.....

S/o/D/o/W/o/.....

hereby request you to supply electrical energy, temporarily for the purpose of..... to the premises (or) location hereinafter described.

2. I / We agree to pay for said energy, service connection charges, the deposit of such security, meter rent, development charges and any other charges as may be demanded in accordance with the scale of rates prescribed under Tamil Nadu Electricity Distribution Code, Supply Code, notifications and orders issued in this regard by Tamil Nadu Electricity Regulatory Commission.

3. I / We wish to be charged under Tariff under schedule of the TNERC tariff order in force.

4. I / We agree to avail temporary supply and utilize the energy in the premises/ location described hereunder for my/our bonafide use.

5. In case, I/We sell or otherwise dispose of the property / vacate the premises while the supply is continued, I/We agree to give one month notice in writing and pay all the arrears to the Licensee, failing which , I/We hold myself/ourselves responsible for the energy consumed in the premises for the entire period of Temporary supply availed. If any due arises in this service connection, I/We agree to include such dues in my/our existing service connections No(s):(if available)

6. Ownership of the premises / location where temporary supply is required:

- a. SF No./ Door No. :
- b. Street :
- c. Town / village :
- d. Land mark of premises :
- e. Taluk :
- f. District :
- g. Owned by (Name in Block Letters) :
- h. Tenanted by (Name in Block Letters) :
- i. Applicant(s)' address for correspondence :
- j. Contact No. and e-mail id :

7. Description of the premises

a. Plot area :

b. Total building area/Floor area of all floors

c. Number of the Floors to be constructed :

(Basement /stilt /ground floor/other floors to be furnished in detail)

d. Whether the planning permission with building plan approval is obtained from competent authority for above mentioned floors and construction :

e. Whether copy of planning permission with building plan approval is enclosed

f. Height of the building as per planning permission/ plan approval :

(If height of the building is more than 15 metre as shown in the planning permission, approval from Electrical Inspector is required)

g. Whether Gen set /Lift is proposed to be erected

(If yes, approval from Electrical Inspectorate to be obtained)

h. Any HT/LT line is passing inside or adjacent to the premise :

(If yes, building should be constructed with adequate safe clearance as per the Safety Regulations in force or otherwise the lines should be got deviated at the cost of Applicant, subject to feasibility)

8. Whether the service connection is required permanently after the period of temporary service connection is over :

If No, (i) Specific purpose for which Temporary supply is requested :

(ii) Period of Temporary supply required :

9. Details of Loads to be Connected:

(A) Lighting	Number of Points	Wattage of points	Total wattage
(i) Lights	-	-	-
(ii) Fans	-	-	-
(iii) Convenient wall plugs-	-	-	-
(B) Power Loads	-	-	-
(i) Motors	-	-	-
(ii) Welding	-	-	-
(iii) Cutting machine	-	-	-
(iv) Portable appliances	-	-	-
(v) Lifts/elevators	-	-	-
(vi) Other apparatus	-	-	-
(vii) Convenient Wall Plugs -	-	-	-

10. Demand applied for in KW :

11. Whether the installation is provided with earth protective device (RCD) as per Tamil Nadu Electricity Distribution Code

12. The wiring has been completed on:

13. Details of existing service connection(s) of the applicant(s), if any

14. Whether any current consumption charges or any other charges are due to TANGEDCO in the name(s) of the applicant(s) or premises :

If yes, give details (with SC No, Name of Section/Circle etc) :

SPACE TO BE PROVIDED BY APPLICANT(S)

1. In storeyed building and for any building / premises requiring LT service connection(s) having either (a) total floor area of 900 square metre and above (excluding the stilt floor / basement floor) or (b) the total demand of all the LT services in the building exceeds 112kW, sufficient space shall be made available free of cost to the Licensee for installing transformers, switchgears etc., as stated in Regulation 29 (11) of the TNE Distribution Code.

2. Space as per the norms specified in Regulation 29(12) of the TNE Distribution Code shall be allotted by the applicant free of cost for establishment of a sub-station/switching station in places requiring service connections (except industrial service connections other than IT related purposes) where either (a) the total demand of all the electrical services in the projects including the loads that will be incident in future exceeds /would exceed 5 MVA or (b) total floor area of 30,000 square metre and above is constructed or proposed to be constructed (excluding the still floor / basement floor).
3. For High Tension Service connections of indoor metering, an electrical room with RCC roof having a clear floor area 5m x 6m with vertical clearance of 3.7 metre between floor and ceiling/ beam bottom with locking facility, exhaust fan and adequate size of cable duct shall be provided at the ground/ basement floor for installing the Licensee's equipment, etc. This room shall be of fireproof and weatherproof; For outdoor metering a clear space of 10 metre x 4 metre or 5 metre x 5 metre open to sky shall be provided. This enclosure shall be at the periphery of the building and shall be cut off from other portions of the premises by fire resistance walls. These areas shall be specifically shown in the plan. Before the plan is sent to the competent authority for approval, it shall be sent to the area engineer of the Licensee and got approved. The point of supply shall be within 30 metre from the main gate easily accessible for lorry movement from public road and clearly visible from the public road and satisfactory with regards to security aspects.

PRECAUTION TO BE ADOPTED BY CONSUMERS, OWNERS, OCCUPIERS, ELECTRICAL CONTRACTORS, ELECTRICAL WORKMEN AND SUPPLIERS

No electrical installation work, including additions, alterations, repairs and adjustments to existing installations, except such replacement of lamps, fans, fuses, switches, domestic appliances of voltage not exceeding 250V and fittings as in no way alters its capacity or character, shall be carried out upon the premises of or on behalf of any consumer, supplier, owner or occupier for the purpose of supply to such consumer, supplier, owner or occupier except by an electrical contractor licensed in this behalf by the State Government and under the direct supervision of a person holding a certificate of competency and by a person holding a permit issued or recognized by the State Government.

I / We certify that we are aware of the above precaution and agree to abide by it.

I / We agree to pay to the Licensee at the applicable tariff/minimum rates/fixed charges/surcharge etc that may be decided by the Commission from time to time.

I / We agree to abide under all specifications, conditions and provisions laid down in Tamil Nadu Electricity Regulatory Supply Code, Distribution Code and the applicable Act, Codes, Rules and Regulations and of any modification or re-enactment thereof for the time being in force and subject to the conditions of revisions, amendments approved from time to time.

(Note: This undertaking does not preclude a separate written contract to be entered with Licensee)

Signature of the Applicant(s)

Name(s) in Block Letters.

Place:

Date:

Note:

1. The application shall be accompanied with the following documents:

- (i) Self attested copy of proof of ownership such as sale deed (or) partition deed (or) gift settlement (or) allotment letter (or) computer patta (or) ownership certificate issued by revenue department officials (or) court judgment or recent property tax receipt.
- (ii) In case of joint property, self attested copies of proof of ownership along with parent documents specified in note (i) above and consent letters from co-owners. If consent letter is not produced, an indemnity bond with enhanced security deposits.
- (iii) If the applicant is not the owner, consent letter from owner in FORM No.5 or valid proof of occupancy and indemnity bond in FORM No.6
- (iv) Plan approval with area earmarked for installing transformer, in case of floor area of 900 square metre and above or the demand exceeds 112KW, in case of LT service connections as per sub regulation 29 (11) of the TNE Distribution Code

OR

Plan approval with area earmarked for establishment of sub-station and road approaches, in case of demand / area exceeds the limit as specified with conditions in sub regulation 29 (12) of the TNE Distribution Code

OR

Plan approval with area earmarked for indoor / outdoor metering , and location of metering point with road approaches in case of HT service connection as specified with conditions in sub regulation 29(14) of the TNE Distribution Code.

FOR LICENSEE'S USE ONLY

ACKNOWLEDGEMENT

Applicant(s)' name :

Address :

Date of receipt:

Reference No. :

Category of Supply :

Signature and seal of Distribution Licensee
Name and designation".

(By order of the Tamil Nadu Electricity Regulatory Commission)

Chennai-600 032.
8th January 2021.

S. CHINNARAJALU,
Secretary,
Tamil Nadu Electricity Regulatory Commission.

EXPLANATORY STATEMENT

In order to ensure that the safety norms and regulations mandated in the CEA regulations such as provision of Residual Current Device inside the premises of consumers and production of necessary approval from Electrical Inspector are to be specifically provided in the Distribution Code for creating awareness among the consumers and for effective implementation to ensure public safety against electric shock and fire hazards. Further the expression 'authority' needs to be defined with clarity.

The LT application needs to be provisioned for joint application by the co-owners as the present format is suitable only for a single applicant.

To define the conditions for metering point location in HT service to make it more practicable so as to ensure that the Licensee is able to reach the location easily during surprise inspection and viable alternate solution where there is no feasibility to erect metering point within the specified distance from main gate or specified location.

To add provision to erect single pole type Transformer inside consumer's premises in addition to existing provision for erecting conventional double pole type.

There being exclusive conditions for Temporary supply, the specific requirements to provide space and other provisions for erection of Transformer or sub-station need to be made more specific to the applicant at the initial stage itself and for that purpose it is proposed to prescribe a separate format for the said category.

To add clarity in computing the difference in cost between the types of sub-station when the applicant chooses to provide space for a type of sub-station other than the type preferred by the Licensee.

The monthly minimum charges to be paid in regard to supply availability notice period has to be made specific to avoid ambiguity.

The amendment seeks to address the above issues.

(By order of the Tamil Nadu Electricity Regulatory Commission)

Chennai-600 032.
8th January 2021.

S. CHINNARAJALU,
Secretary,
Tamil Nadu Electricity Regulatory Commission.